



## COS CONSULTANCY SERVICES

Authority's Engineer - Kerala State

( Ministry of Road Transport & Highways )

State Head Quarters :

'OLIVET'

T.C. 15/1029, Tagore Nagar Lane - 1

Vazhuthacaud, Thiruvananthapuram - 695 014

Telefax No : 0471 - 2735335

E-mail : cosaekerala@gmail.com

Ref: AE/Kerala/PC Canal/2015/028

dated: 06.11.2015

To  
The Managing Partner,  
M/s EKK& Company,  
IInd Floor, Municipal Building,  
A.M. Road, Perumbavoor,  
Ernakulum

Kind Attn: Mr. Sanju Muhammed

Dear Sir,

**Sub:-** Job no. 017-KL-2014-831 Construction of 2-lane Bridge over Ponnani Cochin Canal (Canoli Canal) and its approaches in aggregate length of 1.54 km of NH-17 (New NH-66) from Km 332/650 to Km 333/900 in the state of Kerala on EPC mode- Source approval for Reinforced Steel from Steel Exchange India Limited - Simhadri TMT Steel Bars-Reg

**Ref:** i) Agreement No 4/SE/NH/CC/Kochi/EPC/3/2015-1 dated 21/05/2015  
ii) Your letter No: EKK/PCC/2015/317 dated 07.08.2015.  
iii) This office letter No: AE/Kerala/PC Canal/2015/010 dated 31.08.2015.  
iv) Your letter No: EKK/PCC/2015/436 dated 26.10.2015.

The source approval for reinforcement steel for Steel Exchange India Limited - Simhadri TMT Steel Bars has been submitted vide reference (iv) cited for approval. On scrutiny of the proposal we have send the clarification based on MoRT&H Specification Clause 1009.3.1 vide reference (iii) cited. The proposal was resubmitted vide reference (iv) cited after duly compliance with certification / declaration of the facilities as contemplated in the CPWD's office memorandum No.DGW/MAN/168 issued by the Director General of Works dated 22.12.2008 under "Modification in special conditions for steel under para 26.2(1) of CPWD works Manual 2007.

Further as per MoRT&H Specification Clause 1009.3.1 is also exhibit that the Engineer may allow the procurement of steel from other suppliers, provided that the reinforcement is manufactured from billets procured from the original producers. In such cases the manufacture's certificate alone shall not be considered as a sufficient and the steel shall be got tested by the Engineer in the NABL accredited laboratories only, as third party check. It shall be ensured that all the test results confirm to IS: 1786 requirements.



**Head Office** : 6/13, Kamaraj Nagar 4th street, Tallakulam, Madurai - 625002, TamilNadu.

Phone : 0452-2538233, 4360959, Fax : 0452 - 2538233, E-mail : coscmd@gmail.com

Under the above circumstances the vendor approval for procuring of reinforcement steel from M/s Steel Exchange India Limited – Simhadri TMT Steel Bars (Fe500, Fe500D, HSCRM (CRS) has been accorded.

The approval has been cancelled at any time if the quality is not meet out the codal requirements.

With Regards

For Authority's Engineer

  
Team Leader

CC to

- 1) The Superintending Engineer (Authority) / NH/CC/Vyttila, for information
- 2) The Regional Officer, MoRT&H, Thiruvananthapuram, for information.
- 3) The Managing Director, COS Consultancy Services, Madurai, for information  
(By e-mail)
- 4) Copy to file