

इंजीनियर्स
इंडिया लिमिटेड
(भारत सरकार का उपक्रम)



ENGINEERS
INDIA LIMITED

(A Govt. of India Undertaking)

VRCF PROJECT, VISAKH REFINERY - VISAKHAPATNAM-530011

Tel: 0891-551-1187; Telefax: 0891-2763971; email: eilvrcfp@rediffmail.com

Dt. 09/09/2005

EIV/6501/3701/0 1619

M/s RVR Projects (P) Ltd.,

9-16-29, C.B.M Compound,

VISAKHAPATNAM-530003

Attn.: Mr. R. Venkateswara Rao, Managing Director

Sub: Unit Civil & Strl. Works in M.S.Block & Building Works for Sub Station and Control Room for VRCFP by M/s RVR- Regarding Reinforcement Steel from M/s Simhadri TMT.

Ref: FOA No.5000170 dtd.09.08.2005 - For Building works of S/S & CR.
FOA No 5000177-HP-46004 dtd. 05.08.2005- For C&S works in NLJ
FOA No.5000169 dtd.09.08.2005 - For C&S works in NIU & FCC

Dear Sir,

This has reference to your various earlier letters and your recent letter no.RVR/HPCL/2005/AKC-31/29/27/22 dtd.06.09.2005 requesting to allow for procuring Reinforcement Steel from M/s Simhadri TMT. Your proposal has been reviewed and you may go ahead with procurement of the same from M/s Simhadri TMT subject to the following conditions:


- i) The ingot/raw materials to be used for re-bar manufacturer shall be from reputed concerns like SAIL, IISCO, TISCO and the same shall be ensured by you. Third Party Inspection agencies (DNV, TUV, SGS, CEIL and URS) shall be deployed who will verify the origin of the raw materials before Inspection Clearance. If felt necessary, TPIA will carryout sample check test for Physical and chemical Properties from Govt. Approved Laboratory for correlation with Test Certificates.
- ii) All documents reviewed and copies endorsed by TPIA along with Delivery Challan /Test Certificates and Inspection Release Notes shall be sent to site along with materials.
- iii) TPIA shall release the material with identification punch on bunch of materials properly strapped and sealed.
- iv) On receipt of materials at site, contractor shall produce documents for EIL inspection and subsequent preparation of IMIR before using the materials. After receipt of materials, samples shall be drawn and tested as per requirement for confirmation of quality.

You are advised to go ahead accordingly.

In addition to the above, we would like to inform you that any delay in complying the above requirement shall not be a reason for not achieving the targeted progress of work.

Thanking you.

Very truly yours.


(B.R. RAJASHEKHAR)
Resident Construction Manager